



# Water Quality Parameter Monitoring Form

## Lead & Copper Rule Corrosion Control

Day	pH	Alk	COND	TEMP	Y/N
1					
2					
3					
4					
5					
6	7.9	88.0	253.9	16.9	Y
7					
8					
9					
10					
11					
12					
13	7.9	90.0	257.6	14.6	Y
14					
15					
16					
17					
18					
19					
20	7.9	93.3	258.1	15.9	Y
21					
22					
23					
24					
25					
26					
27					
28	7.9	89.3	258.2	14.1	Y
29					
30					
31					

<<Have minimums been met for this day?

County: Columbia Agency: COLUMBIA COUNTY

**ENTRY POINT**

**EP-A**

**PWS ID 4193427**

**DYNO NOBEL INC**

Sample period: May 2024  
Month/Year

Number of excursions during this month: 0

*(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.*

**Reference**

Minimum Water Quality Parameter(s) as set by State:

pH 7.2

Print Name: Stephanie Andrews

Signature: [Signature]

Date & Phone#: 06/14/24 (503) 366-8920

Send to DWP within 10 days after end of sampling period.

(No = N = Excursion) Total N's 0