



Water Quality Parameter Monitoring Form Lead & Copper Rule Corrosion Control

Day	pH	Alk	COND	TEMP	Y/N
1	7.48	82.3	246.5	15.9	Y
2					
3					
4					
5					
6					
7					
8					
9	7.78	78.4	240.5	23.7	Y
10					
11					
12					
13					
14					
15	7.84	77.2	242.8	19.5	Y
16					
17					
18					
19					
20					
21					
22	7.85	82.2	240.6	21.0	Y
23					
24					
25					
26					
27					
28					
29	7.77	82.4	241.1	16.6	Y
30					
31					

<<Have
minimums
been met for
this day?

County: Columbia Agency: COLUMBIA COUNTY

ENTRY POINT
EP-A
PWS ID 4193427
DYNO NOBEL INC

Sample period: July 2024
Month/Year

Number of excursions during this month: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.

Reference

Minimum Water Quality
Parameter(s) as set by State:

pH 7.2

Print Name: Stephanie Andrews

Signature: [Signature]

Date & Phone#: 8/6/24 503-366-8920

Send to DWP within 10 days after end of
sampling period.

(No = N = Excursion) Total N's 0