



Water Quality Parameter Monitoring Form

Lead & Copper Rule Corrosion Control

Day	pH	Alk	COND	TEMP	Y/N
1					
2					
3					
4					
5	7.99	83.6	248.8	12.7	Y
6					
7					
8					
9					
10	7.78	79.7	243.8	13.1	Y
11					
12					
13					
14					
15					
16					
17					
18	7.83	80.2	247.7	14.6	Y
19					
20					
21					
22					
23					
24	7.80	80.4	244.7	14.0	Y
25					
26					
27					
28					
29					
30					
31					

<<Have minimums been met for this day?

County: Columbia Agency: COLUMBIA COUNTY

ENTRY POINT

EP-A

PWS ID 4193427

DYNO NOBEL INC

Sample period: February 2025
Month/Year

Number of excursions during this month: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.

Reference

Minimum Water Quality Parameter(s) as set by State:

pH 7.2

Print Name: Stephanie Andrews

Signature: [Signature]

Date & Phone#: 3/5/25 503-366-8920

Send to DWP within 10 days after end of sampling period.

(No = N = Excursion) Total N's 0