



# Water Quality Parameter Monitoring Form

## Lead & Copper Rule Corrosion Control

Day	pH	Alk	COND	TEMP	Y/N
1					
2	7.84	81.2	213.9	14.3	Y
3					
4					
5					
6					
7					
8	7.75	79.1	211.9	16.0	Y
9					
10					
11					
12					
13					
14					
15					
16	7.82	81.6	221.6	16.0	Y
17					
18					
19					
20					
21					
22	8.04	86.7	231.5	15.3	Y
23					
24					
25					
26					
27					
28					
29					
30					
31	7.6	92.2	226.1	15.3	Y

<<Have minimums been met for this day?

County: Columbia Agency: COLUMBIA COUNTY

**ENTRY POINT**

**EP-A**

**PWS ID 4193427**

**COLUMBIA RIVER NITROGEN, LLC**

Sample period: December 2025  
Month/Year

Number of excursions during this month: 0

*(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.*

*Reference*

Minimum Water Quality Parameter(s) as set by State:

pH 7.2

Print Name: Stephanie Andrews

Signature: [Signature]

Date & Phone#: 1/7/26 503-366-8920

Send to DWP within 10 days after end of sampling period.

(No = N = Excursion) Total N's 0