

Day	pH	Alk	Phos	Other	Y/N
1	7		2.7		Y
2					
3					
4					
5					
6					
7					
8	7		2.7		Y
9					
10					
11					
12					
13					
14					
15					
16					
17	7		2.7		Y
18					
19					
20					
21					
22					
23					
24	7		2.7		Y
25					
26					
27					
28					
29					
30					
31					

<<Have minimums been met for this day?

ENTRY POINT

PWS ID: 41 93711

System Name: CORVALLIS WALDORF SCHOOL

Entry Point: A - BOILER ROOM DIST.

Sample Period: FEBRUARY 2021
 Month/Year

Number of excursions* during this month: 0
 (Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0
 (Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH 7
 Alk (Alkalinity)
 PO4 1 (Orthophosphate)
 Other ()

Print Name: TIM LOVE
 Signature: *Tim Love*
 Date: 3/1/2021

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's 0