

Day	pH	Alk	Phos	Other	Y/N
1					
2	7		2.9		Y
3					
4					
5					
6					
7					
8					
9	7		2.9		Y
10					
11					
12					
13					
14					
15					
16	7		2.9		Y
17					
18					
19					
20					
21					
22					
23	7		2.9		Y
24					
25					
26					
27					
28					
29					
30					
31					

<<Have minimums been met for this day?

ENTRY POINT

PWS ID: 41 93711

System Name: CORVALLIS WALDORF SCHOOL

Entry Point: A - BOILER ROOM DIST.

Sample Period: August 2021
Month/Year

Number of excursions* during this month: 0
 (Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0
 (Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH 7
 Alk (Alkalinity)
 PO4 1 (Orthophosphate)
 Other (_____)

Print Name: Tim Love
 Signature: Tim Love
 Date: 9/2/2021

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's 0