

Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1					
2					
3					
4					
5					
6	7		2.8		Y
7					
8					
9					
10					
11					
12					
13					
14	7		2.8		Y
15					
16					
17					
18					
19					
20					
21					
22					
23					
24					
25	7		2.7		Y
26					
27					
28					
29	7		2.9		Y
30					
31					

<<Have minimums been met for this day?

ENTRY POINT

PWS ID: 41 937111

System Name: CORVALLIS WALDORF SCHOOL

Entry Point: A - BOILER ROOM DIST.

Sample Period: July 2022
Month/Year

Number of excursions* during this month: 0
(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

- For OHA use only

Minimum Water Quality Parameters as set by

pH 7
Alk (Alkalinity)
PO4 1 (Orthophosphate)
Other ()

Print Name: TIM LOVE
Signature: Timothy Slow
Date: 7/29/2022

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's 0