

Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1					
2					
3	7		2.8		Y
4					
5					
6					
7					
8					
9					
10					
11	7		2.7		Y
12					
13					
14					
15					
16					
17					
18					
19					
20					
21	7		2.7		Y
22					
23					
24					
25					
26					
27					
28					
29					
30					
31	7		2.7		Y

<<Have minimums been met for this day?

ENTRY POINT

PWS ID: 41 93711

System Name: CORVALLIS WALDDORF SCHOOL

Entry Point: A - BOILER ROOM DIST

Sample Period: October 2022
Month/Year

Number of excursions* during this month: 0
(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH 7
Alk (Alkalinity)
PO4 1 (Orthophosphate)
Other (_____)

Print Name: TRM Love
Signature: Tim Love
Date: 10/31/2022

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's 0