

Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1					
2					
3					
4					
5	7		2.6		Y
6					
7					
8					
9					
10					
11					
12					
13					
14					
15					
16					
17					
18					
19	7		2.6		Y
20					
21					
22					
23					
24					
25					
26					
27	7		2.5		Y
28					
29					
30					
31					

<<Have minimums been met for this day?

ENTRY POINT

PWS ID: 41 93711

System Name: CORVALLIS WALDORF SCHOOL

Entry Point: A - BOILER ROOM DIST

Sample Period: April 2023
Month/Year

Number of excursions* during this month: _____
(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH 7
Alk (Alkalinity)
PO4 1 (Orthophosphate)
Other (_____)

Print Name: Tim Love

Signature: _____

Date: _____

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's 0