

Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1					
2					
3					
4					
5	6.8		2.6		N
6					
7	6.8		2.6		N
8					
9					
10	6.8		2.5		N
11					
12	6.8		2.5		N
13	6.8				N
14	6.8				N
15					
16					
17	6.8				N
18					N
19	6.9				
20					
21	6.9		2.3		N
22					
23					
24	6.8				N
25	6.8				N
26					
27					
28	6.9		2.0		N
29					
30					
31	6.9		2.0		N

<<Have minimums been met for this day?

ENTRY POINT

PWS ID: 41 937111

System Name: CORVALLIS WALDORF SCHOOL

Entry Point: A - BOILER ROOM DIST.

Sample Period: July 2023
Month/Year

Number of excursions* during this month: 31
(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH	7	
Alk		(Alkalinity)
PO4	1	(Orthophosphate)
Other		(_____)

Print Name: TIM LOVE
Signature: Tim Love
Date: 8/7/2023

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's 31