

Day	pH	Alk	Phos	Other	Y/N
1	6.8		2.0		N
2	6.9		2.0		N
3	6.9		2.0		N
4					
5					
6					
7	6.9		2.0		N
8	6.8		2.1		N
9					
10	6.8		2.1		N
11					
12					
13					
14	6.8		2.1		N
15					
16	6.8		2.1		N
17					
18					
19					
20					
21	6.8		2.1		N
22					
23	6.8		2.1		N
24					
25	6.8		2.1		N
26					
27					
28					
29	6.9		2.1		N
30	6.9		2.0		N
31					

<<Have minimums been met for this day?

### ENTRY POINT

PWS ID: 41 93711

System Name: CORVALLIS WALDORF SCHOOL

Entry Point: A - BOILER ROOM DIST

Sample Period: Aug 2023  
Month/Year

Number of excursions\* during this month: 31  
(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: \_\_\_\_\_  
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

RECEIVED

SEP 08 2023


For OHA use only

Data Mgmt & Compliance  
Drinking Water Program

Minimum Water Quality Parameters as set by

pH	7	
Alk		(Alkalinity)
PO4	1	(Orthophosphate)
Other		(_____)

Print Name: Tim Love

Signature: 

Date: 8.31.23

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's 31