

Day	pH	Alk	Phos	Other	Y/N
1					
2					
3					
4	6.9		2.15		N
5					
6					
7	6.9		2.15		N
8					
9					
10					
11	6.8		2.15		N
12					
13	6.8		2.16		N
14					
15	6.8		2.15		N
16					
17					
18	6.9		2.13		N
19					
20	6.9		2.16		N
21					
22					
23					
24					
25	6.8		2.14		N
26					
27	6.8		2.02		N
28					
29					
30					
31					

<<Have minimums been met for this day?

ENTRY POINT

PWS ID: 41 9 3 7 1 1

System Name: CORVALLIS WALDORF SCHOOL

Entry Point: A - BOILER ROOM DIST

Sample Period: September 2023  
Month/Year



Number of excursions\* during this month: 30  
(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: \_\_\_\_\_  
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

RECEIVED  
OCT 05 2023

For OHA use only

Data Mgmt & Compliance  
Drinking Water Program

Minimum Water Quality Parameters as set by

pH	7	
Alk		(Alkalinity)
PO4	1	(Orthophosphate)
Other		(_____)

Print Name: Jeff Cogan

Signature:

Date: 9/2/23

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's 30