

| Day | pH | Alk | Phos | Other | Y/N |
|-----|-----|-----|------|-------|-----|
| 1 | | | | | |
| 2 | | | | | |
| 3 | 6.9 | | 2.02 | | N |
| 4 | | | | | |
| 5 | | | | | |
| 6 | 6.9 | | 1.93 | | N |
| 7 | | | | | |
| 8 | | | | | |
| 9 | 6.9 | | 1.86 | | N |
| 10 | | | | | |
| 11 | 6.9 | | 1.89 | | N |
| 12 | | | | | |
| 13 | 6.9 | | 2.01 | | N |
| 14 | | | | | |
| 15 | | | | | |
| 16 | 7.0 | | 2.06 | | Y |
| 17 | | | | | |
| 18 | 7.0 | | 1.89 | | Y |
| 19 | | | | | |
| 20 | 6.9 | | 1.86 | | N |
| 21 | | | | | |
| 22 | | | | | |
| 23 | 6.9 | | 1.89 | | N |
| 24 | | | | | |
| 25 | 6.8 | | 1.83 | | N |
| 26 | | | | | |
| 27 | 6.8 | | 2.02 | | N |
| 28 | | | | | |
| 29 | | | | | |
| 30 | 6.8 | | 1.96 | | N |
| 31 | | | | | |

<<Have minimums been met for this day?

ENTRY POINT

PWS ID: 41 9 3 7 1 1

System Name: CORVALLIS WALDORF SCHOOL

Entry Point: A - BOILER ROOM DIST

Sample Period: October 2023

Month/Year

Number of excursions* during this month: _____
(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: _____
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

RECEIVED
NOV 02 2023
Data Mgmt & Compliance
Drinking Water Program

| | | |
|-------|---|------------------|
| pH | 7 | |
| Alk | | (Alkalinity) |
| PO4 | 1 | (Orthophosphate) |
| Other | | (_____) |

Print Name: Jeff Cygan
Signature: _____
Date: 10/31/23

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's 28