

Day	pH	Alk	Phos	Other	Y/N
1	6.9		1.90		N
2					
3	6.8		1.92		N
4					
5					
6	6.9		2.06		N
7					
8					
9	6.9		1.91		N
10					
11					
12					
13	6.9		1.88		N
14					
15	6.9		1.87		N
16					
17	6.9		1.94		N
18					
19					
20	6.8		1.83		N
21					
22	6.9		1.82		N
23					
24					
25					
26					
27	6.8		1.77		N
28					
29	6.8		1.81		N
30					
31					

<<Have minimums been met for this day?

ENTRY POINT

PWS ID: 41 93711

System Name: CORVALLIS WALDORF SCHOOL

Entry Point: A - BOILER ROOM DIST

Sample Period: November 2023  
Month/Year

Number of excursions\* during this month: 30  
(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: \_\_\_\_\_  
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are counted.)

For OHA use only

RECEIVED

DEC 07 2023

Data Mgmt & Compliance  
Drinking Water Program

Minimum Water Quality Parameters as set by

pH	7.0	
Alk		(Alkalinity)
PO4	1.0	(Orthophosphate)
Other		(_____)

Print Name: Jeff Cygan

Signature: \_\_\_\_\_

Date: 12/4/23

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's 30