

RECEIVED

JAN 04 2024

JAN 04 2024

Day	pH	Alk	Phos	Other	Y/N
1					
2					
3					
4	6.9		1.83		N
5					
6	7.0		1.71		Y
7					
8	7.0		1.74		Y
9					
10					
11	7.0		1.76		Y
12					
13					
14	7.0		1.59		Y
15					
16					
17					
18					
19					
20	7.0		1.77		Y
21					
22					
23					
24					
25					
26					
27	6.9		1.72		N
28					
29					
30					
31					

<<Have minimums been met for this day?

Certification Drinking Water Services

RECEIVED ENTRY POINT

PWS ID: 41 93711

System Name: CORVALLIS WALDORF SCHOOL

Entry Point: A - BOILER ROOM DIST

Sample Period: December 2023
Month/Year

Number of excursions* during this month: 29
(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: _____
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH
 Alk (Alkalinity)
 PO4 (Orthophosphate)
 Other

Print Name: Jeff Cygan
 Signature:
 Date: 1.2.24

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's