

RECEIVED

FEB 05 2024

Certification

Drinking Water Services

| Day | pH | Alk | Phos | Other | Y/N |
|-----|-----|-----|------|-------|-----|
| 1 | | | | | |
| 2 | 7.0 | | 1.62 | | Y |
| 3 | | | | | |
| 4 | | | | | |
| 5 | 6.9 | | 1.71 | | N |
| 6 | | | | | |
| 7 | | | | | |
| 8 | 6.9 | | 1.72 | | N |
| 9 | | | | | |
| 10 | 6.9 | | 1.69 | | N |
| 11 | | | | | |
| 12 | | | | | |
| 13 | | | | | |
| 14 | | | | | |
| 15 | | | | | |
| 16 | | | | | |
| 17 | 6.9 | | 1.61 | | N |
| 18 | | | | | |
| 19 | 6.9 | | 1.74 | | N |
| 20 | | | | | |
| 21 | | | | | |
| 22 | 6.9 | | 1.72 | | N |
| 23 | | | | | |
| 24 | 6.9 | | 1.84 | | N |
| 25 | | | | | |
| 26 | 6.9 | | 1.64 | | N |
| 27 | | | | | |
| 28 | | | | | |
| 29 | 6.9 | | 1.61 | | N |
| 30 | | | | | |
| 31 | 6.9 | | 1.60 | | N |

<<Have minimums been met for this day?

ENTRY POINT

PWS ID: 41

9 3 7 1

System Name: CORVALLIS WALDORF SCHOOL

Entry Point: A - BOILER ROOM DIST.

Sample Period: January 2024
Month Year

Number of excursions* during this month: 30
(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: _____
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

| | | |
|-------|---|------------------|
| pH | 7 | |
| Alk | | (Alkalinity) |
| PO4 | 1 | (Orthophosphate) |
| Other | | () |

Print Name: Jeff Cogan

Signature: _____

Date: 1/31/24

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's **30**