

RECEIVED

MAR 04 2024

Certification
Drinking Water Services

Day	pH	Alk	Phos	Other	Y/N
1					
2	6.8		1.60		N
3					
4					
5	6.9		1.67		
6					
7	6.9		1.64		N
8					
9	6.9		1.67		N
10					
11					
12	6.9		1.63		N
13					
14	6.9		1.56		N
15					
16	6.8		1.64		N
17					
18					
19					
20	6.8		1.21		N
21					
22					
23	6.8		1.40		N
24					
25					
26	6.9		1.69		N
27					
28	6.9		1.53		N
29					
30					
31					

<<Have minimums been met for this day?

ENTRY POINT

PWS ID: 41

System Name: CORVALLIS WALDORF SCHOOL

Entry Point: A - BOILER ROOM DIST:

Sample Period: February 2024
Month/Year

Number of excursions* during this month: 29
(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months:
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH	<input type="text" value="7"/>	
Alk	<input type="text"/>	(Alkalinity)
PO4	<input type="text" value="1"/>	(Orthophosphate)
Other	<input type="text"/>	()

Print Name: Jeff Coggins

Signature: [Signature]

Date: 2.29.24

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's