

RECEIVED

APR 05 2024

Day	pH	Alk	Phos	Other	Y/N
1	6.9		1.64		N
2					
3					
4	6.9		1.60		N
5					
6	6.9		1.55		N
7					
8	6.9		1.47		N
9					
10					
11	6.9		1.37		N
12					
13	6.9		1.24		N
14					
15	7.0		1.09		Y
16					
17					
18	7.0		1.13		Y
19					
20	6.9		1.09		N
21	6.9		1.21		N
22					
23					
24					
25	6.9		1.18		N
26					
27					
28	6.9		1.15		N
29					
30					
31					

<<Have minimums been met for this day?

ENTRY POINT

Certification Drinking Water Services

PWS ID: 41 9 3 7 1 1

System Name: Corvallis Waldorf School

Entry Point: A. Boiler Room

Sample Period: March 2024
Month/Year

Number of excursions* during this month: _____
(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: _____
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH	7.0	
Alk		(Alkalinity)
PO4	1.0	(Orthophosphate)
Other		(_____)

Print Name: Jeff Gygis

Signature: _____

Date: 4.1.2024

Send to DWP within 10 days after end of sampling period

= N = Excursion) Total N's 28