

| Day | pH | Alk | Phos | Other | Y/N |
|-----|-----|-----|------|-------|-----|
| 1 | | | | | |
| 2 | 6.9 | | 1.26 | | N |
| 3 | | | | | |
| 4 | | | | | |
| 5 | | | | | |
| 6 | | | | | |
| 7 | | | | | |
| 8 | 6.9 | | 1.30 | | N |
| 9 | | | | | |
| 10 | 6.9 | | 1.37 | | N |
| 11 | | | | | |
| 12 | 6.9 | | 1.38 | | N |
| 13 | | | | | |
| 14 | | | | | |
| 15 | 6.9 | | 1.47 | | N |
| 16 | | | | | |
| 17 | 6.9 | | 1.35 | | N |
| 18 | | | | | |
| 19 | 6.9 | | 1.40 | | N |
| 20 | | | | | |
| 21 | | | | | |
| 22 | 6.9 | | 1.40 | | N |
| 23 | | | | | |
| 24 | 6.9 | | 1.41 | | N |
| 25 | | | | | |
| 26 | 6.9 | | 1.39 | | N |
| 27 | | | | | |
| 28 | | | | | |
| 29 | 6.9 | | 1.53 | | N |
| 30 | | | | | |
| 31 | | | | | |

<<Have minimums been met for this day?

ENTRY POINT

Certification Drinking Water Services

PWS ID: 41 9 3 7 1 1

System Name: Corvallis Waldorf School

Entry Point: A-Boiler Room - Dist.

Sample Period: April 2024
 Month/Year

Number of excursions* during this month: _____
 (Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: _____
 (Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

| | | |
|-------|-----|------------------|
| pH | 7.0 | |
| Alk | | (Alkalinity) |
| PO4 | 1.0 | (Orthophosphate) |
| Other | | (_____) |

Print Name: Jeff Cygan

Signature: _____

Date: 4/30/2024

Send to DWP within 10 days after end of sampling period

(N = Excursion) Total N's