

RECEIVED

JUL 05 2024

Certification Drinking Water Services

Day	pH	Alk	Phos	Other	Y/N
1					
2					
3	6.9		1.36		N
4					
5	6.9		1.47		N
6					
7	6.9		1.49		N
8					
9					
10	6.9		1.48		N
11					
12					
13					
14	6.9		1.44		N
15					
16					
17	6.9		1.46		N
18					
19	6.9		1.43		N
20					
21					
22					
23					
24	6.9		1.46		N
25					
26	6.9		1.40		N
27					
28	6.9		1.38		N
29					
30					
31					

<<Have minimums been met for this day?

### ENTRY POINT

PWS ID: 41

System Name: CORVALLIS WALDORF SCHOOL

Entry Point: A - BOILER ROOM DIST

Sample Period: June 2024  
Month/Year



Number of excursions\* during this month: 30  
(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: \_\_\_\_\_  
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

#### Minimum Water Quality Parameters as set by

pH	<input type="text" value="7"/>	
Alk	<input type="text"/>	(Alkalinity)
PO4	<input type="text" value="1"/>	(Orthophosphate)
Other	<input type="text"/>	(_____)

Print Name: Jeff Cygan

Signature: \_\_\_\_\_

Date: 7-1-24

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's