

RECEIVED
 AUG 06 2024
 Certification Drinking Water Services

Day	pH	Alk	Phos	Other	Y/N
1	6.9		1.48		N
2					
3	6.9		1.46		N
4					
5					
6					
7					
8	6.9		1.44		N
9					
10					
11					
12	6.9		1.48		N
13					
14					
15					
16					
17					
18	6.9		1.49		N
19					
20					
21					
22					
23					
24	6.9		1.44		N
25					
26					
27					
28					
29					
30	6.9		1.42		N
31					

<<Have minimums been met for this day?

ENTRY POINT

PWS ID: 41

System Name: Corvallis Waldorf School

Entry Point: A - Boiler Room

Sample Period: July 2024
Month/Year

Number of excursions* during this month: 31

(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months:

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH	<input type="text" value="7.0"/>	
Alk	<input type="text"/>	(Alkalinity)
PO4	<input type="text" value="1.0"/>	(Orthophosphate)
Other	<input type="text"/>	()

Print Name: Jeff Cygan

Signature: [Signature]

Date: 7.31.24

Send to DWP within 10 days after end of sampling period

(N = Excursion) Total N's