

Lead & Copper Rule Corrosion Control

RECEIVED

OCT 03 2024

Day	pH	Alk	Phos	Other	Y/N
1					
2	6.9		1.22		N
3					
4					
5					
6	6.9		1.20		N
7					
8					
9					
10					
11	6.9		1.18		N
12					
13					
14					
15					
16					
17					
18			1.39		N
19					
20			1.44		N
21					
22					
23					
24	7.8		1.42		Y
25			1.51		
26					
27					
28					
29					
30			1.60		
31					

<<Have minimums been met for this day?

ENTRY POINT

Certification Drinking Water Services

PWS ID: 41 93711

System Name: CORVALLIS WALDORF SCHOOL

Entry Point: A - BOILER ROOM DIST.

Sample Period: September 2024
Month/Year

Number of excursions* during this month: 29
(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: _____
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH	7	
Alk		(Alkalinity)
PO4	1	(Orthophosphate)
Other		(_____)

Print Name: Jeff Cygan

Signature: *[Signature]*

Date: 9.30.24

Send to DWP within 10 days after end of sampling period

*No = N = Excursion) Total N's 29