

RECEIVED

NOV 04 2024

Certification Drinking Water Services

Day	pH	Alk	Phos	Other	Y/N
1					
2			1.55		
3					
4					
5					
6					
7	7.5		1.62		Y
8					
9					
10	7.3		1.69		Y
11					
12					
13					
14	7.4		1.74		Y
15					
16					
17	7.3		1.72		Y
18					
19					
20					
21	7.4		1.70		Y
22					
23	7.4		1.74		Y
24					
25					
26					
27					
28	7.4		1.72		Y
29					
30	7.4		1.72		Y
31					

<<Have minimums been met for this day?

ENTRY POINT

PWS ID: 41 93711

System Name: CORVALLIS WALDORF SCHOOL

Entry Point: A - BOILER ROOM DIST

Sample Period: October 2024  
Month/Year

Number of excursions\* during this month: 6

(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: \_\_\_\_\_

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH	7	
Alk		(Alkalinity)
PO4	1	(Orthophosphate)
Other		(_____)

Print Name: Jeff Cygan

Signature: *Jeff Cygan*

Date: 10.30.24

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's 6