

RECEIVED

DEC 05 2024

Certification Drinking Water Services

Day	pH	Alk	Phos	Other	Y/N
1	7.4		1.62		Y
2					
3					
4	7.4		1.65		Y
5					
6					
7	7.5		1.67		Y
8					
9					
10					
11	7.5		1.72		Y
12					
13					
14					
15					
16					
17					
18	7.5		1.81		Y
19					
20	7.5		1.81		Y
21					
22					
23					
24					
25					
26	7.5		2.12		Y
27					
28					
29	7.5		2.14		Y
30					
31					

<<Have minimums been met for this day?

ENTRY POINT

PWS ID: 41 93711

System Name: CORVALLIS WALDORF SCHOOL

Entry Point: A - BOILER ROOM DIST.

Sample Period: November 2024  
Month/Year


Number of excursions\* during this month: 0  
(Count the number of days when any WQ was less than the minimum required)

Total excursions during the previous 5 months: \_\_\_\_\_  
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

*For OHA use only*

Minimum Water Quality Parameters as set by

pH	7	
Alk		(Alkalinity)
PO4	1	(Orthophosphate)
Other		( )

Print Name: Jeff Cuger  
Signature:   
Date: 12.2.24

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's 0