

RECEIVED
JAN 02 2025
Certification Drinking Water Services

Day	pH	Alk	Phos	Other	Y/N
1					
2	7.6		2.19		Y
3					
4					
5					
6	7.6		2.22		Y
7					
8					
9	7.6		2.27		Y
10					
11					
12					
13	7.6		2.29		Y
14					
15					
16	7.7		2.32		Y
17					
18	7.6		2.24		Y
19					
20	7.6		2.20		Y
21					
22					
23					
24					
25					
26					
27					
28	7.6		2.16		Y
29					
30	7.7		2.14		Y
31					

<<Have minimums been met for this day?

ENTRY POINT

PWS ID: 41 9 3 7 1 1

System Name: CORVALLIS WALDORF SCHOOL

Entry Point: A - BOILER ROOM DIST.

Sample Period: December 2024
Month/Year

Number of excursions* during this month: 0
(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: _____
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH	7	
Alk		(Alkalinity)
PO4	1	(Orthophosphate)
Other		(_____)

Print Name: Jeff Cygija

Signature: _____

Date: 12/30/24

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's 0