

RECEIVED
FEB 04 2025
Certification Drinking Water Services

Day	pH	Alk	Phos	Other	Y/N
1					
2	7.7		2.11		Y
3					
4					
5					
6	7.7		2.13		Y
7					
8					
9	7.6		1.98		Y
10	7.6		1.94		Y
11					
12					
13	7.6		1.93		Y
14					
15	7.6		1.95		Y
16					
17	7.6		1.89		Y
18					
19					
20					
21	7.7		1.90		Y
22					
23	7.7		1.89		Y
24					
25					
26					
27	7.5		1.83		Y
28					
29	7.6		1.74		Y
30					
31	7.6		1.73		Y

<<Have minimums been met for this day?

ENTRY POINT

PWS ID: 41 9 3 7 1 1

System Name: CORVALLIS WALDORF SCHOOL

Entry Point: A - BOILER ROOM DIST

Sample Period: January 2025
Month/Year

Number of excursions* during this month: 0
(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: _____
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH	7	
Alk		(Alkalinity)
PO4	1	(Orthophosphate)
Other		(_____)

Print Name: Jeff Cygan
Signature: *Jeff Cygan*
Date: 1/31/25

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's 0