

RECEIVED

MAR 03 2025

Drinking Water Services

Day	pH	Alk	Phos	Other	Y/N
1					
2					
3					
4					
5	7.6		1.83		Y
6					
7	7.6		1.87		Y
8					
9					
10	7.6		1.93		Y
11	7.6		1.99		Y
12					
13					
14	7.6		1.97		Y
15					
16					
17					
18	7.7		1.99		Y
19					
20	7.7		1.95		Y
21					
22					
23					
24	7.7		1.88		Y
25					
26	7.7		1.84		Y
27					
28	7.7		1.82		Y
29					
30					
31					

<<Have minimums been met for this day?

ENTRY POINT

PWS ID: 41 93711

System Name: Corvallis Waldorf School

Entry Point: A - Boiler Room

Sample Period: February 2025
Month Year


Number of excursions* during this month: 0
 (Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: _____
 (Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH	7.0	
Alk		(Alkalinity)
PO4	1.0	(Orthophosphate)
Other		(_____)

Print Name: Jeff Cygan
 Signature: 
 Date: 2.28.25

Send to DWP within 10 days after end of sampling period

= N = Excursion) Total N's 0