

RECEIVED

MAY 09 2025

Certification Drinking Water Services

Day	pH	Alk	Phos	Other	Y/N
1					
2					
3					
4					
5					
6					
7	7.8		1.71		Y
8					
9	7.9		1.59		Y
10					
11	7.8		1.57		Y
12					
13					
14					
15	7.8		1.74		Y
16					
17					
18	7.8		1.73		Y
19					
20					
21	7.9		1.70		
22					
23					
24	7.9		1.65		Y
25					
26					
27					
28	7.9		1.67		Y
29					
30	7.9		1.64		Y
31					

<<Have minimums been met for this day?

ENTRY POINT

PWS ID: 41 **93711**

System Name: **CORVALLIS WALDORF SCHOOL**

Entry Point: **A - BOILER ROOM DIST.**

Sample Period: **April 2025**
Month/Year

Number of excursions* during this month:

(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months:

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH	7	
Alk		(Alkalinity)
PO4	1	(Orthophosphate)
Other		()

Print Name: **Jeff Cygan**

Signature: 

Date: **5/1/25**

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's **0**