

Lead & Copper Rule Corrosion Control

RECEIVED
JUN 12 2025
Certification Drinking Water Services

Day	pH	Alk	Phos	Other	Y/N
1					
2					
3					
4					
5	7.8		1.52		Y
6					
7					
8					
9	7.8		1.61		Y
10					
11					
12	7.8		1.60		Y
13					
14					
15					
16	7.7		1.58		Y
17					
18					
19	7.5		1.57		Y
20					
21					
22					
23	7.7		1.60		Y
24					
25					
26					
27					
28	7.5		1.59		Y
29					
30	7.7		1.57		Y
31					

<<Have
minimums
been met for
this day?

ENTRY POINT

PWS ID: 41 9 3 7 1 1

System Name: Corvallis Waldorf School

Entry Point: A - Boiler Room Dist.

Sample Period: May 2025
Month/Year

Number of excursions* during this month: _____

(Count the number of days when any WQP was
less than the minimum required)

Total excursions during the previous 5 months: _____

(Over 9 excursions in 6 months is a violation. Entry
Point and Distribution excursions are cumulative)

For OHA use only

**Minimum Water Quality
Parameters as set by**

pH 7.0
Alk _____ (Alkalinity)
PO4 1.0 (Orthophosphate)
Other _____ (_____)

Print Name: Jeff Cygan

Signature: _____

Date: 6.2.25

Send to DWP within 10 days after end of
sampling period

(Y = N = Excursion) Total N's 0