

RECEIVED

AUG 14 2025

Certification Drinking Water Services

Day	pH	Alk	Phos	Other	Y/N
1					
2	7.7		1.30		Y
3					
4					
5					
6					
7	7.6		1.19		Y
8					
9					
10					
11					
12					
13					
14	7.6		1.12		Y
15					
16					
17					
18	7.6		1.08		Y
19					
20					
21					
22					
23					
24					
25					
26					
27					
28					
29					
30					
31					

<<Have minimums been met for this day?

### ENTRY POINT

PWS ID: 41 9 3 7 1 1

System Name: Corvallis Waldorf School

Entry Point: A - Boiler Room - Dist

Sample Period: July 2025  
Month/Year

Number of excursions\* during this month: 0

(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: \_\_\_\_\_

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

### Minimum Water Quality Parameters as set by

pH 7.0

Alk \_\_\_\_\_ (Alkalinity)

PO4 1.0 (Orthophosphate)

Other \_\_\_\_\_ (\_\_\_\_\_)

Print Name: Jeff Cygan

Signature: \_\_\_\_\_

Date: 8.5.25

Send to DWP within 10 days after end of sampling period

(0 = N = Excursion) Total N's 0