

Lead & Copper Rule Corrosion Control

RECEIVED
NOV 03 2025

Certification Drinking Water Services

Day	pH	Alk	Phos	Other	Y/N
1					
2	7.8		1.64		Y
3					
4					
5					
6					
7	8.0		1.68		Y
8					
9					
10	7.9		1.69		Y
11					
12					
13					
14	8.0		1.73		Y
15					
16					
17	8.0		1.78		Y
18					
19					
20	8.0		1.81		Y
21					
22	8.0		1.84		Y
23					
24					
25					
26					
27	8.0		1.84		Y
28					
29					
30	8.0		1.81		Y
31					

(Y = N = Excursion) Total N's

<<Have
minimums
been met for
this day?

ENTRY POINT

PWS ID: 41

System Name: Corvallis Waldorf School

Entry Point: A - Boiler Room

Sample Period: October 2025

Month/Year

Number of excursions* during this month: 8

(Count the number of days when any WQP was
less than the minimum required)

Total excursions during the previous 5 months: _____

(Over 9 excursions in 6 months is a violation. Entry
Point and Distribution excursions are cumulative)

For OHA use only

**Minimum Water Quality
Parameters as set by**

pH	<input type="text" value="7.0"/>	
Alk	<input type="text"/>	(Alkalinity)
PO4	<input type="text" value="1.6"/>	(Orthophosphate)
Other	<input type="text"/>	(_____)

Print Name: Jeff Cygan

Signature: 

Date: 10.30.25

Send to DWP within 10 days after end of
sampling period