

Lead & Copper Rule Corrosion Control

RECEIVED
DEC 05 2025

Certification Drinking Water Services

Day	pH	Alk	Phos	Other	Y/N
1					
2					
3	7.9		1.81		Y
4					
5					
6	7.7		1.90		Y
7					
8					
9					
10	7.8		1.84		Y
11					
12					
13	8.0		1.97		Y
14					
15					
16					
17					
18					
19					
20	7.9		1.94		Y
21					
22					
23					
24	7.9		1.90		Y
25					
26					
27					
28					
29					
30					
31					

(= N = Excursion) Total N's

<<Have
minimums
been met for
this day?

PWS ID: 41

9 3 7 1 1

ENTRY POINT

System Name: Corvallis Wildcat School

Entry Point: A- Boiler Room

Sample Period: Nov. 2025

Month/Year

Number of excursions* during this month: _____

(Count the number of days when any WQP was
less than the minimum required)

Total excursions during the previous 5 months: _____


(Over 9 excursions in 6 months is a violation. Entry
Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality
Parameters as set by

pH	<u>7.0</u>	
Alk		(Alkalinity)
PO4	<u>1.0</u>	(Orthophosphate)
Other		(_____)

Print Name: Jeff Cugan

Signature: 

Date: 12-2-25

Send to DWP within 10 days after end of
sampling period