

RECEIVED  
 MAR 05 2026  
 Certification Drinking Water Services

Day	pH	Alk	Phos	Other	Y/N
1					
2	7.8		2.04		Y
3					
4					
5					
6					
7					
8					
9	7.9		2.02		Y
10					
11					
12	7.9		1.92		Y
13					
14					
15					
16					
17	7.8		1.84		Y
18					
19					
20					
21					
22					
23	7.8		1.64		Y
24					
25					
26	7.8		1.36		Y
27					
28					
29					
30					
31					

<<Have minimums been met for this day?

**ENTRY POINT**

PWS ID: 41 93711

System Name: Corvallis Waldorf School

Entry Point: A- Boiler Room

Sample Period: February 2026  
 Month/Year

Number of excursions\* during this month: 0  
 (Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: \_\_\_\_\_  
 (Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

**Minimum Water Quality Parameters as set by**

pH 7.0  
 Alk   (Alkalinity)  
 PO4 1.0 (Orthophosphate)  
 Other   ( )

Print Name: Jeff Cygan

Signature: [Signature]

Date: 3.2.26

Send to DWP within 10 days after end of sampling period

( ) = N = Excursion) Total N's 0