

RECEIVED
 APR 06 2026
 Certification Drinking Water Services

Day	pH	Alk	Phos	Other	Y/N
1					
2	7.8		1.19		Y
3					
4					
5	7.8		1.30		Y
6					
7					
8					
9	7.7		1.54		Y
10					
11					
12	7.8		1.51		Y
13					
14					
15					
16	7.8		1.62		Y
17					
18	7.8		1.72		Y
19					
20	7.8		1.81		Y
21					
22					
23					
24					
25					
26	7.8		1.92		Y
27					
28					
29					
30	7.8		2.01		Y
31					

<<Have minimums been met for this day?

ENTRY POINT

PWS ID: 41 93711

System Name: Corvallis Waldorf School

Entry Point: A. Boiler Room

Sample Period: March 2026
 Month/Year

Number of excursions* during this month: 0
 (Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: _____
 (Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH 7.0
 Alk (Alkalinity)
 PO4 1.0 (Orthophosphate)
 Other (_____)

Print Name: Jeff Cygan
 Signature: [Signature]
 Date: 3.30.26

Send to DWP within 10 days after end of sampling period

(i) = N = Excursion) Total N's 0