

21

Day	pH	Alk	Phos	Other	Y/N
5-7 1	8.3	0.5	1.0		Y
5-14 2	7.8	0.4	1.0		Y
5-21 3	7.6	0.3	1.0		Y
5-27 4	7.8	0.3	1.0		Y
5					
6					
7					
8					
9					
10					
11					
12					
13					
14					
15					
16					
17					
18					
19					
20					
21					
22					
23					
24					
25					
26					
27					
28					
29					
30					
31					

<<Have minimums been met for this day?

County: Benton Agency: BENTON COUNTY

ENTRY POINT

EP-A

PWS ID 4193712

RECEIVED JUN 01 2021

Data Mgmt & Compliance Drinking Water Program

MUDDY CREEK CHARTER SCHOOL

Sample period: May 2021
 Month/Year

Number of excursions during this month: 0
 (Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.

Reference

Minimum Water Quality Parameter(s) as set by State:

pH

PO4 (Orthophosphate)

Print Name: Jeff Cygan

Signature: [Signature]

Date & Phone#: 5-28-21 541-760-3937

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's