

Water Quality Parameter Monitoring Form  
**Lead & Copper Rule Corrosion Control**

Day	pH	<del>Alk</del> Phos	Other	Y/N
1				
2				
3	7.8	0.6	1.0	Y
4				
5				
6				
7				
8				
9				
10				
11	7.7	0.4	1.0	Y
12				
13				
14				
15				
16				
17				
18	7.6	0.3	1.0	Y
19				
20				
21				
22				
23				
24	7.6	0.3	1.0	Y
25				
26				
27				
28				
29				
30	7.5	0.3	1.0	Y
31				

(No = N = Excursion) Total N's

<<Have minimums been met for this day?

County: Benton Agency: BENTON COUNTY

**ENTRY POINT**

EP-A

PWS ID 4193712

MUDDY CREEK CHARTER SCHOOL

Sample period: June 2021  
 Month/Year

Number of excursions during this month: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.

RECEIVED  
 JUL 09 2021

Data Mgmt & Compliance  
 Drinking Water Program

Reference

Minimum Water Quality Parameter(s) as set by State:

pH

PO4  (Orthophosphate)

Print Name: Jeff Cygan

Signature: [Signature]

Date & Phone#: 6-30-21 541.760.3937

Send to DWP within 10 days after end of sampling period