

Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1					
2	7.4	0.6	1.5		Y
3					
4					
5					
6					
7					
8	7.5	0.8	1.0		Y
9					
10					
11					
12					
13	7.5	0.8	1.0		Y
14					
15	7.5	0.8	1.0		Y
16					
17					
18	7.5	0.8	1.0		Y
19					
20					
21	7.4	0.8	1.0		Y
22					
23	7.4	0.8	1.0		Y
24					
25					
26					
27					
28	7.5	0.8	1.0		Y
29					
30					
31					

(No = N = Excursion) Total N's

<<Have minimums been met for this day?

County: Benton Agency: BENTON COUNTY

ENTRY POINT RECEIVED  
EP-A  
OCT 04 2021

PWS ID 4193712

MUDDY CREEK CHARTER SCHOOL  
Data Mgmt & Compliance Drinking Water Program

Sample period: September 2021  
Month/Year

Number of excursions during this month: \_\_\_\_\_

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.

Reference

Minimum Water Quality Parameter(s) as set by State:

pH

PO4  (Orthophosphate)

Print Name: Jeff Cogan

Signature: \_\_\_\_\_

Date & Phone#: 9-30-21 541.760.3937

Send to DWP within 10 days after end of sampling period