

Day	pH	Alk	Phos	Other	Y/N
1					
2	7.74	0.24	2.23		Y
3					
4					
5					
6					
7					
8	7.82	0.16	2.24		Y
9					
10					
11					
12					
13					
14					
15					
16	7.81	0.19	2.16		Y
17					
18					
19					
20					
21					
22					
23					
24	7.51	0.84	2.46		Y
25					
26					
27					
28	7.56	0.43	2.36		Y
29					
30					
31					

<<Have minimums been met for this day?

County: Benton Agency: BENTON COUNTY

ENTRY POINT

EP-A

PWS ID 4193712

MUDDY CREEK CHARTER SCHOOL

Sample period: February 2022
 Month Year

Number of excursions during this month: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.



Reference

Data Mgmt & Compliance
 Drinking Water Program

Minimum Water Quality Parameter(s) as set by State:

pH

PO4 (Orthophosphate)

Print Name: Jeff Cygan

Signature: [Signature]

Date & Phone#: 2-28-22 (541) 782.0877

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's