

Day	pH	Alk	Phos	Other	Y/N
1					
2					
3					
4					
5	7.68	0.54	2.79		Y
6					
7					
8					
9					
10					
11	7.59	0.58	2.14		Y
12					
13					
14					
15					
16					
17					
18					
19					
20	7.51	0.42	2.06		Y
21					
22					
23					
24					
25					
26					
27					
28					
29					
30					
31	7.56	0.36	2.12		Y

<<Have minimums been met for this day?

County: Benton Agency: BENTON COUNTY

ENTRY POINT
EP-A

PWS ID 4193712

MUDDY CREEK CHARTER SCHOOL

Sample period: May 2022
Month/Year

Number of excursions during this month: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.



Reference Data Mgmt & Compliance Drinking Water Program

Minimum Water Quality Parameter(s) as set by State:

pH 7.0

PO4 1. (Orthophosphate)

Print Name: Jeff Cygan

Signature: [Signature]

Date & Phone#: 5-31-2022 541-752-0377

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's 0