

Day	pH	Alk	Phos	Other	Y/N
1					
2	7.82	0.39	1.71		Y
3					
4					
5					
6					
7					
8					
9					
10	7.76	0.64	2.42		Y
11					
12					
13					
14	7.73	0.52	2.39		Y
15					
16					
17					
18					
19					
20					
21	7.68	0.49	2.37		Y
22					
23					
24					
25					
26					
27					
28	7.58	0.28	2.16		Y
29					
30					
31					

<<Have minimums been met for this day?

County: Benton Agency: BENTON COUNTY

ENTRY POINT

EP-A


PWS ID 4193712

MUDDY CREEK CHARTER SCHOOL

Sample period: June 2022
 Month/Year

Number of excursions during this month: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.



Data Mgmt & Compliance
 Drinking Water Program

Reference

Minimum Water Quality Parameter(s) as set by State:

pH

PO4 (Orthophosphate)

Print Name: Jeff Cygan

Signature: [Signature]

Date & Phone#: 6-28-22 541-752-0377

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's