

CI

Day	pH	Alk	Phos	Other	Y/N
1					
2					
3	7.76	6.31	2.93		Y
4					
5					
6					
7	7.60	0.25	2.26		Y
8					
9					
10					
11	7.70	0.23	2.04		Y
12					
13					
14					
15					
16					
17	7.66	0.32	2.06		Y
18					
19					
20					
21	7.64	0.49	2.03		Y
22					
23					
24					
25					
26					
27					
28					
29	7.70	0.36	2.16		Y
30					
31					

<<Have minimums been met for this day?

County: Benton Agency: BENTON COUNTY

ENTRY POINT

EP-A

PWS ID 4193712

MUDDY CREEK CHARTER SCHOOL

Sample period: November 2022
 Month/Year

Number of excursions during this month: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.

RECEIVED
 DEC 06 2022

Reference

Data Mgmt & Compliance
 Drinking Water Program

**Minimum Water Quality
 Parameter(s) as set by State:**

pH

PO4 (Orthophosphate)

Print Name: Jeff Cygan
 Signature: [Signature]
 Date & Phone#: 11-30-2022

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's