

Day	pH	<del>Alk</del> Phos	Other	Y/N
1				
2				
3				
4	7.87	0.18	1.74	Y
5				
6				
7				
8				
9				
10				
11				
12	7.84	0.17	1.66	Y
13				
14				
15				
16				
17	7.82	0.12	1.55	Y
18				
19				
20				
21				
22				
23				
24	7.79	0.16	1.54	Y
25				
26				
27				
28	7.76	0.19	1.50	Y
29				
30				
31				

<<Have minimums been met for this day?

County: Benton Agency: BENTON COUNTY

**ENTRY POINT**

**EP-A**

**PWS ID 4193712**

**MUDDY CREEK CHARTER SCHOOL**

Sample period: April 2023  
 Month/Year

Number of excursions during this month: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.

Reference

**Minimum Water Quality Parameter(s) as set by State:**

pH

PO4  (Orthophosphate)

Print Name: Jeff Cygan  
 Signature: [Signature]  
 Date & Phone#: 5-1-23 541.752.0377

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's