

Water Quality Parameter Monitoring Form
Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1					
2					
3	7.72	0.29	1.53		Y
4					
5					
6					
7					
8					
9					
10					
11					
12	7.68	0.33	1.60		Y
13					
14					
15					
16					
17					
18	7.66	0.40	1.61		Y
19					
20					
21					
22					
23					
24	7.63	0.31	1.64		Y
25					
26					
27					
28					
29					
30	7.57	0.34	1.66		Y
31					

<<Have minimums been met for this day?

County: Benton Agency: BENTON COUNTY

ENTRY POINT RECEIVED
 EP-A JUN 08 2023

PWS ID 4193712
 Data Mgmt & Compliance
 Drinking Water Program

MUDDY CREEK CHARTER SCHOOL

Sample period: May 2023
 Month/Year

Number of excursions during this month: 0
 (Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative).
 An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.

Reference

Minimum Water Quality Parameter(s) as set by State:

pH

PO4 (Orthophosphate)

Print Name: Jeff Cysan

Signature: [Signature]

Date & Phone#: 6.3.23 541.752.0377

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's