

Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1					
2	7.45	.45	1.75		
3					
4					
5					
6					
7					
8	7.47	.67	1.3		
9					
10					
11					
12	7.5	.57	1.4		
13					
14					
15					
16					
17					
18					
19	7.49	.75	1.3		
20					
21					
22					
23					
24	7.5	.67	1.2		
25					
26					
27					
28					
29	7.57	.74	1.3		
30					
31					

<<Have minimums been met for this day?

County: Benton Agency: BENTON COUNTY

**ENTRY POINT**

**EP-A**

**PWS ID 4193712**

**MUDDY CREEK CHARTER SCHOOL**

Sample period: JAN 24  
Month/Year

Number of excursions during this month: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.

Reference

Minimum Water Quality Parameter(s) as set by State:

pH

PO4  (Orthophosphate)

Print Name: Kalesh Weader

Signature: [Signature]

Date & Phone#: Feb 1 2024

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's