

Day	pH	Alk	Phos	Other	Y/N
1					
2					
3	7.35	0.11	1.20		
4					
5					
6					
7					
8					
9					
10	7.24	0.10	1.18		
11					
12					
13					
14					
15					
16					
17	7.33	0.12	1.31		
18					
19					
20					
21					
22					
23					
24	7.24	0.10	1.22		
25					
26					
27					
28					
29					
30					
31	7.22	0.11	1.26		

<<Have minimums been met for this day?

County: Benton Agency: BENTON COUNTY

**ENTRY POINT**

**EP-A**

**PWS ID 4193712**

**MUDDY CREEK CHARTER SCHOOL**

Sample period: JAN. / 25  
 Month/Year

Number of excursions during this month: \_\_\_\_\_

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.

Reference

**Minimum Water Quality Parameter(s) as set by State:**

pH

PO4  (Orthophosphate)

Print Name: SAM WATSON

Signature: SAM WATSON

Date & Phone#: 1/31/25

Send to DWP within 10 days after sampling period

(N = Excursion) Total N's