

Day	pH	ALK	Phos	Other	Y/N
1					
2	7.28	0.12	1.61		
3					
4					
5					
6					
7					
8	7.20	0.10	1.52		
9					
10					
11					
12					
13	7.32	0.14	1.70		
14					
15					
16					
17					
18					
19	7.47	0.11	1.63		
20					
21					
22					
23					
24					
25					
26					
27					
28					
29					
30					
31					

<<Have
minimums
been met for
this day?

County: Benton Agency: BENTON COUNTY

ENTRY POINT

EP-A

PWS ID 4193712

MUDDY CREEK CHARTER SCHOOL

Sample period: June / 25
Month/Year

Number of excursions during this month: _____

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative).
An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.

Reference

**Minimum Water Quality
Parameter(s) as set by State:**

pH 7.0

PO4 1. (Orthophosphate)

Print Name: Sam Watson

Signature: Sam Watson

Date & Phone#: 6/27/25

Send to DWP within 10 days after e
sampling period

= N = Excursion) **Total N's**