

Day	pH	Alk	Phos	Other	Y/N
1					
2					
3					
4					
5					
6	7.0				y
7					
8					
9					
10	7.0				y
11					
12					
13					
14	7.0				y
15					
16					
17	7.0				y
18					
19	7.1				y
20					
21					
22					
23					
24	7.0				y
25					
26					
27					
28					
29					
30					
31	7.1				y

<<Have minimums been met for this day?

County: Marion Agency: Clackamas County

ENTRY POINT
EP-A

PWS ID 4193717

Renaissance Public Academy

Sample period: January 2022
Month/Year

Number of excursions during this month: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.

Reference _____

Minimum Water Quality Parameter(s) as set by State:

pH 7.0

Alk (Alkalinity)

Print Name: Phillip Merrill

Signature: *Phillip Merrill*

Date & Phone#: 2-7-2022

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) **Total N's** 0