

Day	pH	Alk	Phos	Other	Y/N
1					
2					
3					
4	7.49	61			y
5					
6					
7					
8					
9					
10					
11					
12					
13					
14					
15					
16					
17					
18					
19					
20					
21					
22					
23					
24					
25	7.45	44			y
26					
27					
28					
29					
30					
31					

<<Have minimums been met for this day?

County: Marion Agency: MARION COUNTY

**ENTRY POINT**

**EP-A**

**PWS ID 4193768**

**ABIQUA SCHOOL**

**Sample period:** January 2021  
 Month/Year

**Number of excursions during this month:** 0

*(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.*



*Reference*

**Minimum Water Quality Parameter(s) as set by State:**

pH 7.2  
 Alk 30.0 (Alkalinity)

**Print Name:** Phillip Merrill

**Signature:** *Phillip Merrill*

**Date & Phone#:** 2-6-2021

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) **Total N's** 0