

Water Quality Parameter Monitoring Form
Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1					
2					
3					
4					
5					
6					
7					
8	7.4	45			y
9					
10					
11					
12	School closed for spring break, from 3-20-2021 to 3-28-21				
13					
14					
15					
16					
17					
18					
19					
20					
21					
22					
23					
24					
25					
26					
27					
28					
29	7.4	48			y
30					
31					

<<Have
minimums
been met for
this day?

County: Marion

Agency: MARION COUNTY

ENTRY POINT

EP-A

PWS ID 4193768

ABIQUA SCHOOL

Sample period: March 2021

Month/Year

Number of excursions during this month: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.



Reference

**Minimum Water Quality
Parameter(s) as set by State:**

pH 7.2

Alk 30.0 (Alkalinity)

Print Name: Phillip Merrill

Signature: Phillip Merrill

Date & Phone#: 4-2-2021

Send to DWP within 10 days after end of
sampling period

(No = N = Excursion) **Total N's** 0