

Water Quality Parameter Monitoring Form
Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1					
2					
3					
4					
5					
6					
7					
8					
9					
10					
11					
12					
13	7.7	38			Y
14					
15					
16					
17					
18					
19					
20					
21					
22					
23					
24					
25					
26					
27	7.1	33			
28					
29					
30					
31					

<<Have minimums been met for this day?

County: Marion Agency: MARION COUNTY

ENTRY POINT

EP-A

PWS ID 4193768

ABIQUA SCHOOL

Sample period: September 2021
 Month/Year

Number of excursions during this month:

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which water quality parameter(s) fall below the minimum set by the State.

Reference

Minimum Water Quality Parameter(s) as set by State:

pH 7.2
 Alk 30.0 (Alkalinity)

Heavy Rain

Print Name: Shane SANCEDO

Signature: [Signature]

Date & Phone#: Sept 21 775.23

Send to DWP within 10 days after end sampling period

No = N = Excursion) Total N's

OHA Drinking Water Program, PO Box 14350, Portland, OR 97293-03
 Phone (971) 673-0405 Website: <http://healthoregon.org/dwp/>

Date	flow meter	gallons since last read	chem tank begin gallons	chem tank end gallons (mix is 4lb soda to 5 gal H2O)	ph at well	Alkalinity at well ppm	ph at boys drinking fountain	Alkalinity at boys drinking fountain	ph at staff room sink	Alkalinity at staff room sink	ph probe calibration	Notes
1												
2												
3												
4												
5												
6												
7												
8												
9												
10												
11												
12												
13	38.119	48.18	21	25	7.7	38						
14												
15												
16												
17												
18												
19												
20												
21												
22												
23												
24												
25												
26												
27	65.344	27,225	10	25	7.13	33						
28												
29												

cont.

Rain

